



ABN 89 163 993 208

Teralba Industries Pty Ltd
15-19 Kialba Road Campbelltown NSW 2560
PO Box 1639 Campbelltown NSW 2560 Australia
National Call: 1300 20 70 20
P +61 (02) 4629 3000 F +61 (02) 4625 4591
E admin@teralba.com www.teralba.com

PRESSURE TESTING REPORT

DIMPLEFLO HEAT EXCHANGER
1U 130T 19 323 500 I

REPORT NUMBER: H19425A
CLIENT: [Signature]
CLIENT ORDER: PO-0027
TERALBA JOB No: DFT19425
UNIT MODEL: 1U 130T 19 323 500
UNIT SERIAL No: DFT19425A (HEX4500)
TEST LOCATION: 15 - 19 Kialba Road, CAMPBELLTOWN NSW 2560

TEST DETAILS

TEST MEDIA: Town Water
TEST DURATION: 30 minutes per side
TEST TEMPERATURE: ~21 °C
GAUGE SERIAL No: 796536
CALIBRATION CERT: A32288PA
REMARKS: Testing carried out in accordance with Australian standard AS1210:2010 Cl 5.10 and Teralba Industries Pty Ltd Work Instruction #47401.

HYDROTEST ACCEPTANCE

Table with 4 columns: TEST PRESSURE (Inner/Primary), 220kPa, TEST PRESSURE (Jacket/Secondary), 1100kPa. Rows include Start Time, Start Pressure, Pressure Test Carried Out By (R. CHHAY), Pressure Test Witnessed by Teralba (R. S. BAKER), and Result (PASSED) with signatures and dates.